



SINCE 1896

REPORT



3933 US ROUTE 11 CORTLAND, NEW YORK 13045

Order No. 3127463

Revised Issue Date: January 25, 2010

Original Issue Date: July 9, 2007

REPORT NO. 3127463CRT-002b

**IMPACT SOUND TRANSMISSION TEST AND
CLASSIFICATION OF ENGINEERED HARDWOOD
FLOORING OVER IMPACTA-REGUPOL PROBASE 6MM
UNDERLAYMENT ON A SIX INCH CONCRETE SLAB**

RENDERED TO

**SOUND SEAL
50 H. P. ALMGREN DRIVE
AGAWAM, MA 01001**

Revision Note: Change in product name.

INTRODUCTION

This report gives the results of an Impact Sound Transmission test and the determination of the Impact Insulation Class of Engineered Hardwood Flooring over IMPACTA-REGUPOL PROBASE 6MM Underlayment. The underlayment was selected and supplied by the client and received at the laboratories on July 2, 2007. The underlayment appeared to be in a new, unused condition.

AUTHORIZATION

Signed Intertek Quotation No. 500038104.

TEST METHOD

The specimen was tested in general accordance with the American Society for Testing and Materials designation ASTM E2179-03, "Standard Test Method for Laboratory Measurement of the Effectiveness of Floor Coverings in Reducing Impact Sound Transmission Through Concrete Floors".

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. Measurement uncertainty budgets have been determined for applicable test methods and are available upon request.

TEST METHOD – Cont'd

Two vertically adjacent rooms are used: the upper one being designated the source room and the lower one the receiving room (10,000 ft³). A standard concrete floor is installed in an opening between them. The rooms and the floor installation are designed so the only significant sound radiation into the receiving room is from the standard concrete floor.

A standard tapping machine is placed and activated on the standard concrete floor and the impact sound pressure levels are measured in the room below. The floor covering to be evaluated is then placed on the standard concrete floor and the impact sound pressure levels measured again.

The differences in impact sound pressure level are used to calculate two single number ratings. The first is an IIC rating calculated for the covering installed on the reference concrete floor. The second rating, Δ IIC, represents the calculated reduction in IIC when the covering is placed on the reference concrete floor, that is the improvement in IIC due to the covering.

DESCRIPTION OF THE FLOOR/CEILING ASSEMBLY

The floor system consisted of a six inch thick concrete slab that forms the horizontal separation between two rooms. The slab is not isolated from the receiving room walls.

DESCRIPTION OF TEST SPECIMEN

The test specimen consisted of 3/8 inch thick Engineered Hardwood Flooring over IMPACTA-REGUPOL PROBASE 6MM thick recycled rubber underlayment laid on the concrete floor.

.

RESULTS OF TEST**ENGINEERED HARDWOOD FLOORING
OVER IMPACTA-REGUPOL PROBASE 6MM UNDERLAYMENT**1/3 Octave Band Sound Pressure
Level dB re 0.0002 Microbar

<u>1/3 Octave Band Center Frequency Hertz</u>	<u>Bare Concrete</u>	<u>Test Specimen on Concrete</u>	<u>Difference In dB</u>	<u>Reference Floor</u>	<u>Calculated Levels</u>
100	61.7	59.9	1.8	67.0	65.2
125	64.3	62.8	1.5	67.5	66.0
160	66.4	64.0	2.4	68.0	65.6
200	67.4	65.9	1.5	68.5	67.0
250	69.1	67.6	1.5	69.0	67.5
315	69.7	68.7	1.0	69.5	68.5
400	70.5	65.6	4.9	70.0	65.1
500	71.0	59.9	11.1	70.5	59.4
630	71.9	55.6	16.3	71.0	54.7
800	73.1	50.9	22.2	71.5	49.3
1000	73.6	44.8	28.8	72.0	43.2
1250	75.2	40.1	35.1	72.0	36.9
1600	77.0	37.7	39.3	72.0	32.7
2000	79.0	38.2	40.8	72.0	31.2
2500	79.3	37.2	42.1	72.0	29.9
3150	78.9	36.1	42.8	72.0	29.2
Impact insulation Class (IIC)*				28	50

Calculated improvement in Impact Insulation Class: IIC 50– IIC 28 = △ IIC 22

*Classified in accordance with ASTM E989-89 (Re-approved 1999), entitled, “Standard Classification for Determination of Impact Insulation Class (IIC)”.

The uncertainty limit of the impact noise test data is less than 3 dB for the 1/3 octave bands centered in the range from 100 to 400 Hz and less than 2.5 dB for the bands centered on the range from 500 to 3150 Hz.

REMARKS

1. Aging Period: None
2. Ambient Temperature: 71°F
3. Relative Humidity: 42%

CONCLUSION

The test method employed for this test has no pass-fail criteria, therefore, the evaluation of the test results is left to the discretion of the client.


Date of Test: July 5, 2007

Report Approved by:



Brian Cyr
Engineer
Acoustical Testing

Report Reviewed By:



James R. Kline
Engineer/Quality Supervisor
Acoustical Testing

Attachments: None